



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Bldg A Adult Bathroom Sink

Date Sampled: 05/31/24

Time Sampled: 06:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138904					
Lead	4-JUN-2024 13:10	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:43	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B Rm 1 Kitchen SinkBldg B Rm Date Sampled: 05/31/24 Time Sampled: 06:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138905					
Lead	4-JUN-2024 13:16	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:44	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B Rm 1 Fountain Date Sampled: 05/31/24 Time Sampled: 06:53

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138906					
Lead	4-JUN-2024 13:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:44	0.111	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B 2nd Floor Tame Rm Sink Date Sampled: 05/31/24 Time Sampled: 06:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138907					
Lead	4-JUN-2024 13:29	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:45	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C Rm 3 Water Fountain Date Sampled: 05/31/24 Time Sampled: 07:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138908					
Lead	4-JUN-2024 13:36	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:45	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C Rm 3 Kitchen Sink Date Sampled: 05/31/24 Time Sampled: 07:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138909					
Lead	4-JUN-2024 13:42	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:45	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

06/07/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Bldg C Rm 5 Water Fountain

Date Sampled: 05/31/24

Time Sampled: 07:14

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138910					
Lead	4-JUN-2024 13:49	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:46	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C Adult Bath Sink

Date Sampled: 05/31/24

Time Sampled: 07:17

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138911					
Lead	4-JUN-2024 14:09	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:46	0.052	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

06/07/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

Sample Location: Field Reagent Blank

Date Sampled: 05/31/24

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138898					
Lead	4-JUN-2024 12:04	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:41	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A Rm 2 Kitchen Sink

Date Sampled: 05/31/24

Time Sampled: 06:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138899					
Lead	4-JUN-2024 12:10	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:41	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A Rm 2 Children Water Fountain Date Sampled: 05/31/24 Time Sampled: 06:38

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138900					
Lead	4-JUN-2024 12:17	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:41	0.293	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A Main Kitchen Sink

Date Sampled: 05/31/24

Time Sampled: 06:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138901					
Lead	4-JUN-2024 12:24	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:42	0.062	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A Rm 4 Water Fountain

Date Sampled: 05/31/24

Time Sampled: 06:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138902					
Lead	4-JUN-2024 12:30	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:42	0.066	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A Rm 6 Water Fountain

Date Sampled: 05/31/24

Time Sampled: 06:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138903					
Lead	4-JUN-2024 12:50	<2.00	ug/L	2.0	15.5	SM3113B
Copper	6-JUN-2024 14:39	0.052	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

06/07/2024

Date



South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer:	Little Lamb Preschool
Contact:	Ruth Piatt
Address:	1005 East Wheat Road Vineyard, NJ 08360
Phone:	Fax: 856 507-9700
Office:	856 692-5390

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W138998	Field Reagent Blank	5/31/24	6:30 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138999	BLDG RM 2 Kitchen Sink		6:35 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139000	BLDG RM 2 Children's Water Fountain		6:38 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139001	BLDG Main Kitchen Sink		6:40 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139002	BLDG RM 4 Water Fountain		6:42 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139003	BLDG RM 6 Water Fountain		6:44 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139004	BLDG Adult Bathroom Sink		6:47 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139005	BLDG RM 1 Kitchen Sink		6:54 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139006	BLDG RM 1 Fountain		6:53 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W139907	BLDG RM 2 Kitchen Sink		6:56 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: DIDRINKING WATER AAQUEOUS SISOL SLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days	Standard		°C
<input type="checkbox"/> Rush turnaround available upon request	NJ DEP Reduced Deliverables		
	NJ DEP Full Deliverables	* HNO3 preserved upon receipt at laboratory	Properly Preserved
	Electronic Data Deliverables		Yes
	PWTA Format		No

Sampled by: (Print) Michael E. Piatt		Received by: (Signature) <i>[Signature]</i>		Date	Time
Sampled by/Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature) <i>[Signature]</i>		6/3/24	1030
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time



South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer:	Little Lamb Preschool
Contact:	Ruth Platt
Address:	1005 East Wheat Road Vineland, NJ 08360
Phone:	Fax: 856 507 9100
Office:	556 692 5390

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W138908	BLDG C RM3 Water Fountain	5/31/24	7:10 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138909	BLDG G RM3 Kitchen Sink		7:12 PM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138910	BLDG C RM5 Water Fountain		7:14 PM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138911	BLDG C Adult Bath Sink		7:17 AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: DIDRINKING WATER AAQUEOUS SISOL SLUDGE GWGROUND WATER SMSURFACE WATER WWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	°C Properly Preserved Yes No

Sampled by: (Print) Michael E Platt	Received by: (Signature) <i>[Signature]</i>	Date: 5/31/24	Time: 7:21 AM
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date: 6/3/24	Time: 10:30
Relinquished by: (Signature)	Received by: (Signature)	Date:	Time: