



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank

Date Sampled: 03/21/21

Time Sampled: 13:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104745					
Lead	29-MAR-2021 14:15	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:51	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A, Rm 2 Kitchen Sink

Date Sampled: 03/21/21

Time Sampled: 13:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104746					
Lead	29-MAR-2021 14:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:52	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A, Rm 2 Children Fountain

Date Sampled: 03/21/21

Time Sampled: 13:37

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104747					
Lead	29-MAR-2021 14:41	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:52	0.251	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A, Main Kitchen Sink

Date Sampled: 03/21/21

Time Sampled: 13:39

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104748					
Lead	29-MAR-2021 14:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A, Rm 4 Water Fountain

Date Sampled: 03/21/21

Time Sampled: 13:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104749					
Lead	29-MAR-2021 14:54	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg A, Rm 6 Water Fountain

Date Sampled: 03/21/21

Time Sampled: 13:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104750					
Lead	29-MAR-2021 15:00	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:53	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

03/31/2021

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Bldg A, Adult Bathroom Sink Date Sampled: 03/21/21 Time Sampled: 13:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104751					
Lead	29-MAR-2021 15:07	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B, Class 1 Kitchen Sink Date Sampled: 03/21/21 Time Sampled: 13:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104752					
Lead	29-MAR-2021 15:13	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B, Class 1 Fountain Date Sampled: 03/21/21 Time Sampled: 13:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104753					
Lead	29-MAR-2021 15:20	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:55	0.165	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg B, Staff/Team Rm Fountain Date Sampled: 03/21/21 Time Sampled: 13:49

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104754					
Lead	29-MAR-2021 15:27	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:56	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C, Rm 3 Water Fountain Date Sampled: 03/21/21 Time Sampled: 13:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104755					
Lead	29-MAR-2021 15:33	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:57	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C, Rm 3 Kitchen Sink Date Sampled: 03/21/21 Time Sampled: 13:54


Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104756					
Lead	29-MAR-2021 15:53	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:57	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

03/31/2021

Date



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Little Lamb Preschool
1005 East Wheat Road
Vineland, NJ 08360
856-692-5390

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Bldg C, Rm 5 Water Fountain Date Sampled: 03/21/21 Time Sampled: 13:58

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104757					
Lead	29-MAR-2021 16:00	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:57	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Bldg C, Adult Bathroom Sink Date Sampled: 03/21/21 Time Sampled: 14:04

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T104758					
Lead	29-MAR-2021 16:20	<2.00	ug/L	2.0	15.5	SM3113B
Copper	29-MAR-2021 13:59	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

03/31/2021

Date